

Height Safety Access System Certificate

New System

Existing System

Client:	Owners of Strata Plan or building owner etc
Site Address:	
System Location:	Roof of the building.
Date Installed:	N/A
Date Certified:	20/03/2018

Systems Tested/Certified						
<input checked="" type="checkbox"/> Anchor Points		<input type="checkbox"/> Life Lines/Static Lines		<input type="checkbox"/> Track Systems		<input type="checkbox"/> Inertia Reels
ANCHOR POINTS - TOTAL QUANTITY		<input style="width: 50px; border: 1px solid black;" type="text" value="22"/>				
Quantity	Anchor Type	Host Structure	Fixing	Rope Access	Fall Arrest	Manufacturer/Code
<input style="width: 40px; height: 20px;" type="text"/>	Eye Bolts			<input type="checkbox"/>	<input type="checkbox"/>	
<input style="width: 40px; height: 20px;" type="text"/>	Surface Mounts			<input type="checkbox"/>	<input type="checkbox"/>	
<input style="width: 40px; height: 20px;" type="text"/>	Through Bolts			<input type="checkbox"/>	<input type="checkbox"/>	
<input style="width: 40px; height: 20px;" type="text"/>	Rafter Anchors			<input type="checkbox"/>	<input type="checkbox"/>	
<input style="width: 40px; height: 20px;" type="text" value="22"/>	Purlin Anchors	Steel Purlin/Steel Roof Sheet Combination	Through Bolt M12	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Unknown

Test Description

- Applied axial pull out of force of 6kn (as per AS/NZS 4488.2 1997 Industrial Rope Access Systems)
- Applied axial pull out of force of 7.5kn (as per AS/NZS 1891.4 2000 Industrial Fall Arrest Systems and Devices)
- Applied axial load force and inspected in accordance with AS/NZS 1981.2 Supp 1 - 2001 Industrial Fall Arrest Systems and Devices - Horizontal Life Lines and Rail Systems
- No Load Test required - Visual Inspection Only

Test Results

Sample No.	Load Applied	Pass / Fail	Anchor Rating (kN)
22x purlin anchor	N/A	Pass	12KN

Test Equipment Used

- | | |
|---|------------------|
| <input type="checkbox"/> Hilti Tester 4 S/N 59604 | Calibration Date |
| <input type="checkbox"/> Load Cell AD 4326A | Calibration Date |
| <input checked="" type="checkbox"/> None Required | |

Attachments

- | | | |
|-----------------------------------|-------------------------------------|--------------------------------------|
| <input type="checkbox"/> Photo(s) | <input type="checkbox"/> Spec Sheet | <input type="checkbox"/> Layout Plan |
|-----------------------------------|-------------------------------------|--------------------------------------|

The Height Safety Access System is to be used by rope access personnel and other competent contractors with current NSW accreditation for work at heights only.

It is compulsory to inspect all parts of the system every 12 months to ensure their continued integrity as a fall arrest / rope access system.

?????????

20 March 2018

Director